

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**CERTIFICATE**

No.911.....

Date:-...19/6/23.....

It is certified that inspection team headed by **Mr. Taufique Ahmed, Executive Officer, Vidya Vihar Pilani, Nagar Palika** (Name of the Officer with designation) with **Mr. Roshan Saini, Sanitary Inspector** (Name of the department / Office) inspected the **Birla School, Pilani**, Ward No. 18, Vidya Vihar, Pilani (Name & address of the school) on ...19/6/23.....(date) and found that the Birla School, Pilani (Name of the School) has safe water drinking water facilities for the students and members of the staff of the institution and is main tanning the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Centre/State/U.T. Govt.

The above certificate is valid for a period ofOne Year.....



Signature with Seal

अधिकाारी अधिकाारी

Name :- Mr. Taufique Ahmed
पिलाणी

Designation:- Executive Officer (N.V.V.P)



To

The Bursar,
Birla School, Pilani,
Ward No. 18,
Vidya Vihar, Pilani – 333031.
(Name & Address of the Institution)



**PRINCIPAL
BIRLA SCHOOL, PILANI
PILANI (RAJ.)**



Manager

**Birla School Pilani
Pilani - 333031 (Rajasthan)
CBSE Affn. No. : 1730009**



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU
CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2022-23/ 871

Date - 17.3.2023

To,
The Principal
Birla School Pilani

Distt:-Jhunjhunu
Tehsil:-Pilani

Ref- Yours letter dated 17-03-23

Date of Exam -17-03-2023

A	Name & Location of Source		Water Sample Mess Birla School	Water Sample D Block Birla School	Water Sample School Block Birla School	Water Sample Water Section Birla School
B	Village/ Town		Pilani	Pilani	Pilani	Pilani
C	Date Of Collection		17-03-23	17-03-23	17-03-23	17-03-23
D	Lab. Sample No.		C-101	C-102	C-103	C-104
Sr. No	Parameters	Required (acceptable limit)	Analysed Value			
1	pH	6.5—8.5	7.71	7.74	7.70	7.70
2	Turbidity[NTU]	5	Nil	Nil	Nil	Nil
3	Temperature[C]	-----	25	25	25	25
4	Colour[Units]	25 Hazen Unit	N.D.	N.D.	N.D.	N.D.
5	Odour	Unobjectionable	None	None	None	None
6	Total Alkalinity[asCaCO ₃]	600	130	130	140	110
7	Total Hardness[asCaCO ₃]	600	50	50	50	50
8	Calcium [as Ca]	75	8	8	8	8
9	Magnesium [as Mg]	30	7.2	7.2	7.2	7.2
10	Chloride[as Cl ⁻]	1000	60	50	60	50
11	Nitrate[as NO ₃ ⁻]	45	14.46	14.00	16.83	13.45
12	Fluoride[as F ⁻]	1.0	0.64	0.66	0.69	0.63
13	Total Dissolved Solids	2000	340	340	370	318

Note: All Results Except pH in mg/L

(S K Sharma)
Junior Chemist

PHED Laboratory Jhunjhunu

Date -

No. Lab. / Chem. /2022-23/

Copy to -

1-The Chief Chemist PHED Raj.Jaipur

2- The Superintending Chemist (HM) PHED Lab Gandhi Nagar Jaipur

Junior Chemist

PHED Laboratory Jhunjhunu

PRINCIPAL
BIRLA SCHOOL PILANI
PILANI (RAJ.)

Manager
Birla School Pilani

Pilani - 333031 (Rajasthan)

CBSE Affn. No. : 1730009